

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7167-1615:0124

Page 1 of 2

CATEGORY: 7167 -- CONTROL UNIT (HOUSEHOLD)

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Model D2212 and D2812 inherently power-limited residential fire alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations.
System components:

- D2212B, D2212BE; Control/Communicator
- D2812P, D2412UE; Control/Communicator
- D2212/D2812; Control/Communicator
- D2412/D2412U/D2812U; Control/Communicator
- D205; Command Center
- D202A/D220A; Command Center
- D133; Relay Module
- D126; 12V, 7Ah Battery
- D1625; AC Transformer
- D110; Tamper Switch
- D164; Phone Cord
- D8103; Enclosure
- D8108A/D8109; Enclosure
- D127; Reversing Relay
- D134; Relay Module
- D208/D208LC; Zone Expander
- D132A; Smoke Detector Reverse Polarity Module
- D1640; AC Transformer
- D8109G/D8109H/D8109L; Enclosures

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the secondary (standby) power supply shall supply energy during power loss to operate a protected premises, central station, or proprietary system for 24 hours or an auxiliary or remote station system for 60 hours in the normal condition followed by not less than 5 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating, and UL label.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

APPROVAL: Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instructions Manual for details.

These control units do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal.

- NOTE:**
1. For household system, **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approved for use in California. This feature shall not be programmed into the unit.
 2. Burglary and other non-fire functions were not examined.
 3. Formerly 7167-0801:143



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division