

Technical Bulletin

B444 LED indicators



BOSCH

Invented for life

Issue severity

- High. Act immediately
- Medium. Bosch Security Systems strongly recommends you take the action described below.
- Low. Advisory

Products affected

- ▶ B444 Cellular Communication Module
- ▶ B444-C Cellular Communication Module

September 15, 2018

Issue

New B444/B444-C Module LED indicators for signal strength might register at marginal levels as indicated on the module by a yellow LED. LEDs might also toggle between green and yellow.

Resolution

LED indicator accuracy will be addressed in the next firmware releases of the B465 Universal Dual Path Communicator, B450 Plug-in Communicator Interface, and B and G Series control panels.

If you are experiencing marginal signal strength and signal quality levels as indicated by a yellow LED, perform some basic communication tests such as email, personal notifications, or a test message to central station in order to verify operational integrity.

Yellow LED occurrences do not necessarily indicate low or poor signal quality.

